

ZAKŁAD IZOLATORÓW ELEKTROTECHNICZNYCH
BOPLAST Sp. z o.o.


Adres:

ul. B.Krzywoustego 1,
tel. +48 59 862 01 86;
www.boplast.pl

84-300 Łęborg
tel. 516 198 886
e-mail: boplast@boplast.pl

POST INSULATORS * BUSHING INSULATORS * INSULATION PRODUCTS * SERVICES

Post insulator 12 kV type JO8-75



1. Insulator material:
epoxy compound
2. Parameters according to PN-90/E06322/01
3. Tested according to PN-91/E-06340
4. Max screw tightening torque:
- M16 - 120 Nm
5. Indoor insulator

Rated insulation voltage	12 kV
Lightning impulse withstand voltage	75 kV
Dry withstand alternate voltage (50Hz, 1 min)	38 kV
Bending strength Po	8 kN
Creepage distance	227 mm
Weight	1 kg